

IF YOU'VE EVER ASKED YOURSELF "WHY?" about something related to structural steel design or construction, *Modern Steel Construction's* monthly Steel Interchange column is for you! Send your questions or comments to solutions@aisc.org.

SCBF X-Brace

Is a one-story X-braced frame permitted for a Special Concentrically Braced Frame?

X-braced frames are permitted for use in SCBF systems; however, each brace must be able to accommodate both the tensile and compressive modes. Tension-only bracing systems are not permitted in SCBF systems. See Section C13.1 in the AISC *Specification for Structural Steel Buildings* (AISC 360-10) accomplished based on a consideration of the relative thicknesses of the elements involved. The number of bolts required can be calculated as

Where P is the required strength (load),

t_f is the thickness of the filler, t_p is the thickness of the plate, flange, or element being connected, and ϕ is the design strength of the bolt. The term in parentheses represents the increase in the number of bolts due to the presence of the fills.

La S. M., P.E.

Evaluation of Existing Structures

Is it permissible to use the ASD provisions of the 2005 AISC Specification to analyze an existing structure designed using the Specification of the 8th edition era? We're currently involved in the renovation of a structure designed and built in 1987/1988, and will need to slightly increase the load on several floor beams. Using the 8th edition steel manual several beams will be overstressed, from 8% to 13%. If the ASD provisions of the 13th edition are used, then these same beams are not overstressed.

Yes, you can use the current *Specification for Structural Steel Buildings* (AISC 360-10) to evaluate existing structures. You can use either the ASD or LRFD load approach to evaluate a structure originally designed using an older ASD *Specification*, as long as you use it consistently on both the load and resistance side of the design equation. Also, you can find provisions that may be helpful specifically when you are doing evaluation and/or repair in Appendix 5—*Evaluation of Existing Structures*—in the 2005 AISC *Specification for Structural Steel Buildings*.

K. G. af, S.E., P.E.

Bolt Hole Sizes

If a fabricator has detailed 7/8-in. diameter holes for 3/4-in. diameter bolts can this still be considered a bearing-type connection? The loads are small—less than 10 kips per connection. It is for a pipe rack. Also, can you use slip-critical connections with galvanized steel?

Section J3.2 of the AISC *Specification for Structural Steel Buildings* (AISC 360-10) states, "Oversized holes are permitted in any or all plies of slip-critical connections, but they shall not be used in bearing-type connections." and "Short-slotted holes are permitted in any or all plies of slip-critical or bearing-type connections. The slots are permitted without regard to direction of loading in slip critical connections, but the length shall be normal to the direction of the load in bearing-type connections."

The first statement prohibits the use of oversized holes in bearing connections. The intention of both statements is to prohibit bearing-type load transfer in a direction where the hole clearance is greater than 1/16 in. From this the 7/8-in. holes would not be permitted in a bearing connection.

Galvanized material is allowed within the faying surface of slip-critical connections. Section J3.8 includes "hot-dipped galvanized and roughened surfaces" as a Class A surface. Section 3.2.2.(c) of the RCSC *Specification for Structural Steel Buildings* (The Bolt Spec.) states, "Galvanized Faying Surfaces: Galvanized faying surfaces shall first be hot-dip

steel interchange

Second-Order Analysis

I attended a seminar on second-order analysis, where I heard that the loads must be multiplied by the alpha value of 1.6 when using ASD for the member design. Do the analysis results get divided by the same value of 1.6 for member design, or are they calculated? I have been using the analysis results as calculated, and not dividing by 1.6.

Yes, if you're using ASD, multiply the loads by 1.6 going into the analysis and then divide the resulting member moments and other force effects by 1.6 for comparison with M / ϕ , etc. This is stated in the last sentence of Section 7.3(a) in AISC *Specification* Appendix 7, if you're using the Direct Analysis Method. If you're using the Effective Length Method, this is Section C2.2a(2).

Brad Davis, P.E., S.E.

Panel Zone Shear Strength

1. Based on AISC 341-05 Section 9.3a, panel zone shear strength is calculated per *Specification* Section J10.6. In J10.6, there are two sets of equations; one assumes panel zone is elastic, the other considers the inelastic overstrength. My question is when to use the inelastic equation.

2. After comparing panel zone shear demand with the column web shear capacity, we may need to provide a doubler plate. To calculate the required thickness of the doubler plate based on the additional strength required, what is the length of doubler plate that can be used? Do you suggest counting the full column depth or using the actual length of the doubler plate, which is (Column depth - 2 × column flange thickness)?

My thoughts are as follows:

1. AISC 341-05 Section 9.3a refers to AISC 360-05 Section J10.6, which provides two options. In the first option, one can do the frame analysis with panel-zone deformations not modeled; in this case the basic form of panel zone shear strength (Equations J10-9 and J10-10) is used. Alternatively, when a more sophisticated analysis that considers the effect of panel-zone deformations is performed, a higher shear strength can be used (Equations J10-11 and J10-12). This higher strength is based upon the deformations (inelastic action) of the panel zone. So, the inelastic equations can be used when you include the deformations in the analysis.

2. The calculations in AISC *Design Examples* (and other examples in AISC literature) implicitly use the full column depth when selecting the web doubler plate thickness. That is, the required thickness is calculated based upon the full depth of the column, and then the additional thickness required is determined by subtracting the column web thickness. The edges of the doubler plate along the column flanges are welded to develop the shear strength of the doubler plate, so I think this is appropriate.

Charlie Casteo, S.E., P.E., P.D.

Conventional Configuration Single-Plate Shear Connections

Design limitations for conventional configuration single-plate shear connections imply that long-slotted holes are not permitted. Why are these not permitted? Also, for the extended configuration, are long-slotted holes permitted? The limitations for the extended configuration refer to AISC *Specification* Section J3.2 requirements, which imply that long-slotted holes may be used. If these are permitted, would they need to be slip critical?

Yes, the procedure presented in the Manual for the conventional

The complete collection of Steel Interchange questions and answers is available online. Find questions and answers related to just about any topic by using our full-text search capability. Visit Steel Interchange online at www.modernsteel.com.

Kurt Gustafson is the director of technical assistance in AISC's Steel Solutions Center. Charlie Carter is vice president and chief structural engineer at AISC. Brad Davis and Larry Muir are part-time consultant to AISC.

Steel Interchange is a forum to exchange useful and practical professional ideas and information on all phases of steel building and bridge construction. Opinions and suggestions are welcome on any subject covered in this magazine.

The opinions expressed in Steel Interchange do not necessarily represent an official position of the American Institute of Steel Construction, Inc. and have not been reviewed. It is recognized that the design of structures is within the scope and expertise of a competent licensed structural engineer, architect or other licensed professional for the application of principles to a particular structure.

If you have a question or problem that your fellow readers might help you solve, please forward it to us. At the same time, feel free to respond to any of the questions that you have read here. Contact Steel Interchange via AISC's Steel Solutions Center:



Steel
SolutionsCenter

One East Wacker Dr., Suite 700
Chicago, IL 60601
tel: 866.ASK.AISC • fax: 312.803.4709
solutions@aisc.org